

MOBILE CATERING VEHICLE / TRAILER SAFETY CHECK

SERIAL N^o **CP44** A003476



This form allows the recording of the results of the required checks as defined by the Gas Safety (Installation and Use) Regulations. Chimney systems, when checked, were inspected visually and checked for satisfactory evacuation of products of combustion, a detailed internal inspection of the chimney system has not been carried out. The information recorded on this form does not confirm that the installation was installed by a person licensed by Gas Safe Register.

VEHICLE / TRAILER OWNER ADDRESS

Name: THOMAS MACKAY
 Address: S PARK ROW
BRETBY
B.O.T
 Postcode: DE5 0RL
 Tel No: _____

DETAILS OF VEHICLE TRAILER (tick appropriate box)

Reg No. or Serial / Chassis No. KHM 168C
 LPG cylinder housing satisfactory NA Yes No
 Fire extinguisher(s) provided Yes No
 Fire blanket provided NA Yes No
 Current safety certificate displayed Yes No
 Safe use of LPG information displayed Yes No

REGISTERED BUSINESS DETAILS

Reg No: PIZZERIA BUFFALA
 Company: S PARK ROW
 Address: BRETBY
B.O.T
 Postcode: DE5 0RL
 Tel No: _____

APPLIANCE DETAILS

APPLIANCE TYPE		Make	Model	Serial No.	Chimney/Flue Type (FLOF/RS)	Is Appliance Secure Yes/No	Is Appliance Isolation Valve Fitted Yes/No	No. of Appliances Listed Below
1	PIZZA OVEN	VALONIANI	UNKNOWN	UNKNOWN	CF	YES	YES	ONE
2								
3								
4								

INSPECTION / SAFETY CHECKS

Ventilation Satisfactory (Yes/No)	Operating Pressure or Heat Input (mbar/kW)	Safety Device(s) Correct Operation (Yes/No/NA)	Visual Condition Satisfactory (Yes/No/NA)	Chimney/Flue Performance (Pass/Fail/NA)	Appliance Serviced (Yes/No)	Appliance Safe (Yes/No)
NO	37MB	YES	YES	PASS	NO	YES

COMBUSTION READING(S)

Initial (If Applicable)	Final (If Applicable)	Appliance Serviced (Yes/No)	Appliance Safe (Yes/No)
NA	NA	NO	YES

SUMMARY

INSTALLATION GENERAL	Yes/No
Cylinder / final connection hoses to installation satisfactory	YES
Does the regulator have an OPSO fitted	YES
ECV accessible and operable	YES
Gas installation pipework (visual inspection) satisfactory	YES
Gas tightness satisfactory	YES/NO/NA
Emergency procedures displayed	YES
Mechanical ventilation interlock operating correctly	NA
CO ₂ Detector satisfactory	YES

APPLIANCE DEFECT(S) IDENTIFIED

REMEDIAL ACTION TAKEN	
1	
2	
3	
4	

DETAILS OF OTHER WORK CARRIED OUT (e.g. service, etc.)

OBSERVATIONS / COMMENTS / REMEDIAL WORK REQUIRED
RECOMMEND SERVICE OF OVEN.

NEXT SAFETY CHECK DUE BEFORE
2015/05

Issued by: A. VANNAN Signed: _____
 Licence No: 649528 Issue Date: 22/5/24
 Received by: T. Mackey Signed: _____
 Tenant / Landlord / Agent / Other (please state) _____ No one present at the time of visit

WARNING NOTICE SERIAL N^o 11

Refer to separate Warning Notice

Key: Top Copy - Operator

Middle Copy - Vehicle/Trailer Owner

Bottom Copy - Registered Business

To re-order quote Ref: CP44

Gas Safe Register is a registered trade mark of the HSE and is used under licence.